

HIGH COURT OF JAMMU AND KASHMIR

(OFFICE OF THE CENTRAL PROJECT COORDINATER e-COURTS)

NIT No.:- TENDER-JKHC/5/2017

Dated:- 01-07-2017

Subject:- Corrigendum to NIT and extension of time.

In the NIT No.:- TENDER-JKHC/5/2017 Dated:- 01-07-2017 published by the High Court, for supply, installation and maintenance of UPS and Scanners for the High Court, the following corrigendum is issued:

In Annexure-1 (Specifications), for UPS, the following specifications are substituted for the earlier specifications:

1. Capacity 600 VA LINE INTERACTIVE
2. Input Voltage and Frequency 140-270 V, 47 to 53 Hz
3. Output Voltage and Frequency (On Mains) 230 +/- 5 % with AVR (Automatic Voltage Regulation), 50 hz +/- synchronized with Input Power Frequency
4. Output Voltage and Frequency (On Battery) 230 V +/- 3% with 50 Hz
5. Backup Time 20 minutes
6. Battery Type Maintenance-free sealed Lead-Acid battery with suspended electrolyte : leak proof
7. Overload Capacity 110%
8. Efficiency 84% or more at Full Load; 80% at Half Load
9. Output Wave type Quasi Sine Wave or better
10. Transfer Time <= 4 milliseconds
11. Load Power Factor 0.6
12. Other Features Cold Start, Auto Start, Generator Compatible, No Load Shutdown
13. Protections from Surge, Short Circuit, Spikes, DC Under voltage and Overload
14. Indicators Mains, On Battery, Charge, Overload
15. Alarms Low Battery, Mains Off, Tripping
16. Operating Environment 0 – 40 °C
17. Operating Relative Humidity 0 – 95%
18. Audible noise at 1 meter from surface of unit; Not more than 50.00 dBA

19. Output Sockets 3 or more with 3 pin
20. OEM Original Equipment Manufacturer (OEM) Product

ALL THE ABOVE SPECIFICATIONS SHOULD BE READ AS
EQUIVALENT OR BETTER.

Bidders who have already submitted their bids have an option to withdraw their bids and resubmit their bids conforming the substituted specifications.

The last date of submission of bids is extended to **21-07-2017 4 PM** and the bids will be opened on **22-07-2017 at 11 am** in presence of the representatives of bidders if they chose so.

Sd/-
Malik Shabir Ahmad

Central Project Coordinator (e-Courts)

High Court of Jammu and Kashmir

Date: 14-07-2017

Place: Srinagar