

# HIGH COURT OF JAMMU & KASHMIR AND LADAKH

\*\*\*\*\*

## TENDER NOTICE

No: HC/JK/ET/01/2026

Date: 20.02.26.

The Registrar General, on behalf of High Court of Jammu & Kashmir and Ladakh invites SEALED *quotations/tenders in two-bid system* from experienced and reputed firms/organizations/Original Equipment Manufacturer (OEM) for the “*Supply, Installation, Commissioning and Maintenance of 2 No. of 6 kVA Rack Mounted UPS with Rack Mounted Battery Bank/s having comprehensive warranty of 5 years.*”

Name of Work	EMD (Rs)	Cost of online Tender Document (Rs.)	Last Date of tender Submission	Time for Completion of the work /project.
Supply, Installation, Commissioning and Maintenance of 2 No. of 6 kVA Rack Mounted UPS with Rack Mounted Battery Bank/s having comprehensive warranty of 5 years.	7000/-	500/-	26 <sup>th</sup> of Feb. 2026 before 11:00 AM.	5 days.

### Eligibility Criteria

1. The bidder should be an authorized dealer/ reseller of OEM & should submit a certificate from the OEM/ MAF in the name of “High Court of J&K and Ladakh” also declaring period of association.
2. The turnover of the bidder from supply of UPS should be more than 5 lakh during the previous financial year. A certificate from the CA should be provided in support of the same, please note.

### Instructions to Bidders

1. Bidders are required to submit their offer in 2(Two) bids, namely “Technical (Unpriced) Bid” & “Commercial (Priced) Bid”.
2. Bids shall be submitted separately in **Two PARTS** in sealed envelopes super scribed with the Tender Document number, Tender due date and time, item and nature of bid & the name and address of the Bidder as under:

Part - I (Envelope No. 1): Technical (Unpriced) Bid & Tender Fee & EMD in the shape of DDs

Part - II (Envelope No. 2): Priced Bid

3. The envelopes containing Part -I, Part -II of bid shall be enclosed in a larger envelope duly sealed and pasted and shall bear the tender Document number, tender due date and time, item and nature of tender & the name and address of the Bidder.
4. Bidder to note that if tender EMD and Tender fee (in the shape of DD) in original is kept in any other envelope and not found in envelope no. 1, the offer of the bidder(s) will be REJECTED during opening.
5. Demand Draft or Pay Order or Bankers' Cheque favouring "The Registrar General, High Court of Jammu, Kashmir & Ladakh, Jammu, towards the tender fees & EMD from a nationalised/scheduled bank, payable at Jammu, shall only be acceptable.
6. Bidder to note that prices are to be quoted in the Format provided in the price schedule formats provided along with the tender without any conditions. Price bids submitted in any other format and conditional price bids will be liable to be rejected. Price bids received in open condition (not in sealed envelope) or kept in any other Part of the bid (i. e, Part - I or II) will also be liable for rejection.
7. If the outer envelope is not sealed and not marked as required, High Court will assume no responsibility for the tender's misplacement or premature opening.
8. Bidders in their own interest shall ensure that they send their tender complete in all respects well in time to reach the specified office within the specified tender due date and time. No relaxation shall be given for delay due to any unforeseen event in submission of tender.
9. Tender document complete in all respects must be submitted to the following address before due date and time:

**Officer of the Registrar (IT),  
High Court of Jammu, Kashmir & Ladakh, Janipur, Jammu**

10. All the pages of the priced bid shall be signed by the authorised signatory. In case all the pages of the priced bids are not signed, the bid shall be rejected.
11. Each Bidder shall submit only one tender. A Bidder who submits more than one tender will be rejected.
12. The rate quoted by the bidder in the commercial bid should be inclusive of all taxes & 5-year on-site comprehensive warranty.

13. A security deposit of 3% shall be submitted by the L1 bidder in the form CDR/FDR and pledged to Registrar General, High Court of J&K and Ladakh, Jammu, valid for a period of 5-years plus 2 months (62 months) as PBG.

14. One 6 kVA UPS shall be supplied and installed at Srinagar wing of the High Court and One unit shall be supplied and installed at Jammu wing of the High Court.

### Technical Specifications

Parameter	Minimum Requirements
Rack Mounted All in One UPS System.	
Capacity	6000VA/6000 W or better
Frequency Range:	Should be 42 Hz – 65 kHz or better
Phase	Single Phase with Ground
Output Voltage	220/240VAC
Power Factor	0.8 or better
Current Crest Ratio	3:1 or better
Efficiency	95% - 98%
Battery Type	Valve-regulated, non-spillable, lead-acid, 9Ah, 192V
Battery Recharge Time	90% within 3 hours or better
Backup Time	100% Load: 10 Minutes or better 50% Load: 20 Minutes or better
Extended Run time	Upto 4 External Battery Cabinets or Better
Hot Swappable Batteries	Yes
Operating Temperature	0 to 40°C
Audible Noise	<55dBA or better
Compliance	CE, CB Report, EAC, UKCA, IEC/EN 62040-1; RoHS, REACH, WEEE
Communication Port	USB

## Annexure I

(To be printed on Company's Letter head, duly signed by the authorised signatory of the company; POA for authorization shall be attached separately)

### Commercial Bid Format

Sr. No.	Component Name	Quantity (A)	Unit Rate (Inclusive of all taxes & 5-year warranty) (B)	Amount (C=AxB)
1.	6 kVA UPS	2		